BANGALORE WATER SUPPLY AND SEWERAGE BOARD

No. BWSSB/CEDTE/ACE(DESIGN)/TA(Design& QA)//2024-25 Dt:Office of the Chief Engineer (Design& QA),Cauvery Bhavan, Bangalore-560009

ADDENDUM-I TO TENDER THROUGH KARNATAKA PUBLIC PROCUREMENT PORTAL ONLY

(www.kppp.karnataka.gov.in)

Ref:-NITNo.:BWSSB/CED&QA/ACE(Design)/ TA/2121/2024-25 Dated:06.11.2024

****

In continuation of the above tender notification was invited vide reference, with respect to Technical Schedule of Work of supply, installation and commissioning of 200HP FCMA soft starter in Hegganahalli pumphouse and new 215HP Capacity pumpsets and accessories at Hosahalli pump house coming under AEE(DE&PS)-2 subdivisionan addendum-I is issued as follows:

Sl.No.	Firm Name	Queries Received	Query Response
1	**M/s.Flow More Limited**	1) Pl confirm the existing Transformer at the site	• Yes there are existing transformer, can visit site for clarification.
		2) Metering cubicle CT's to be replaced if it is new type Metering cubicle, else new metering cubicle to be installed. Pl clarify	• No need of replacement of CTs and PTs
		3) Since the project is involved with 500 KVA Transformer, CEIG Commissiong approval to be obtained mandatorily. Since the CEIG inspection is involved, Tool Kit, Fire fighting Equipment's & earthing materials are to installed as per IE Rule which are mandatory. Above equipment's are not considered in the Tender BOQ. Pl clarify	• Safety equipment's are present in the pumphouse
		4) It will helpful if the rating of dismantling pump set is mentioned, to get clarity of the existing Control panel & Starter is suitable. Pl clarify	• Existing control panel and starter are as per the required pumpset capacity.

		5) Abstract of Documents Submission. a) Pl clarify Point #8-AATC b) Pl clarify Point # 12-UDIN	• **AATC- Assessed available tender capacity for detail information read 3.7 clause Qualification of the Tenderer page.8 of Bid document** • **UDIN**- UDIN is an initiative taken by ICAI in an effort to curb misrepresentation by third persons posing as Chartered Accountants who forge signatures on documents to mislead authorities.
		6) As per Tender Clause Section 9 it has been mentioned that prices should be exclusive of GST but as per price bid it has been mentioned that prices should be inclusive of all applicable Taxes Pl clarify	• As per the GO ಸುತ್ತೋಲೆ ಸಂ.ಅಇ417 ವೆಚ್ಚ-12/2024 ದಿನಾಂಕ:09.08.2024 Tender is invited with exluding GST.Tenderer should quote the rates excluding GST.
		7) Payment Terms not mentioned in the Bid, Pl clarify	• Payment condition remain same as per bid document
		8) Since we are Electrical contractor, Can we submit our bid alongwith KPWD Contractor consent Letter, Pl note min civil work for Pumps Foundation are involved, Pl clarify whether KPWD License is required to unload	• Contractors should have Electrical license (Class I) in KSEI/ KPWD or any other authorized department

Other conditions remain unaltered.

Chief Engineer(Design&QA)
BWSSB

NOTE: ADDENDUM-I supersedes the NIT No. BWSSB/CED&QA/ACE(DESIGN)/TA/ 2121/2024-25 Dt:06.11.2024